

## EC-CERTIFICATE OF CONFORMITY

**Certificate No: 0809 - CPD - 0818**

In compliance with Council Directive 89/106/EEC of December 21, 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction products

### **Natural smoke and heat exhaust ventilator windows**

**made of aluminium profiles with three hinges locating at lowed edge of the casing,  
opening outwards, having weight highest 58 kg,  
with electrically working Roca SuperMaster chain opener 800mm/24vdc, 600 mm/24vdc or 450 mm/24  
vdc depending on window height and having property profile  
WL 3000 - SL 0 - T(00) – RE 100 – B 300 and  
reaction to fire classes of the components A1 - F**

placed on the market by

**Tikli Group Oy  
Yhdystie 40  
FI-62900 Vimpeli**

and produced in the factory

**Tikli Group Oy, Yhdystie 40, FI-62900 Vimpeli**

are submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No. 0809 –VTT Expert Services Ltd– has performed the initial type testing for the relevant characteristics of the product, the initial inspection of the factory and the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that the provisions concerning the attestation of conformity and the performances described in the Annex ZA of the standard

### **EN 12101-2: 2003**

were applied and that the products fulfil all the prescribed requirements.

This certificate was first issued on June 28, 2013 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Espoo 28.06.2013



Tiina Ala-Outinen  
Service Manager



Liisa Rautiainen  
Assessment Manager